



## Installation and Maintenance Groth Model 6000 & 6100 Gauge Hatches

### Installation

1. Remove protective packaging material.
2. Mount unit in vertical position on tank nozzle using a gasket between the flanges and proper size bolts and nuts.
3. All nuts should be tightened evenly.

### Maintenance

It is important to regularly inspect unit for damaged diaphragm, O-Ring, or seat where applicable.

### Notice

Please indicate size, model number and serial number when ordering replacement parts.

### Warning

Sparking can occur if steel components make contacting during opening and closing.